

FIRE SAFETY CERTIFICATE

No. 755/2025

Dated: 23/01/2025

Certified that the Sanjeevan English Medium School at 1363, A ward, Rankala Road, Shivaji Peth, Kolhapur. Comprised of G+2 owned/occupied by Mr. Amar Prataprao Sarnaik have complied with the fire prevention and fire safety requirements in accordance with rule of State/UT Fire Service Rules and verified by the officers concerned of Fire Service on 16/01/2025 (date of inspection) in the presence of Mrs. Apurva Amar Sarnaik (name and address of the Manager / Secretary or his representative) and that the building/ premises is fit for occupancy upto classes B from standard 1st to 10th standard with effect from 22/01/2025 for a period of One year in accordance with rule and subject to compliance of specific condition as appended:-

1. Fire Extinguisher- ABC (6 kg) - 02 Nos., ABC (04 kg)-02 Nos.
2. Fire Pump and Accessories- Main Pump 450LPM-01 Nos.
3. Hydrant Riser & Hose Reel System- Hose Reel Hose 30 Mtr-03 Nos.

Issued on 23/01/2025 at Kolhapur by

- Strike out whichever is not applicable.

Signature with Seal:

Name : Manish Ranbise

Designation: Chief Fire Office

Name & Address of Department/ Office:

Kolhapur Municipal Corporation



To

Sanjeevan English Medium School,
1363, A Ward, Rankala Road,
Shivaji Peth, Kolhapur.

ENDORSEMENT

The No Objection Certificate issued by Fire Service stand cancelled an annulled due to

.....
.....
(reasons to be recorded).

(Name and designation of the authorized signatory)

- ❖ The filled-up certificate should be either In Hindi or English. If it is Issued in vernacular language, translated notarized version in English be upload along with the original vernacular certificate as a single pdf.


Principal

Sanjeevan English Medium School
Kolhapur.


Manager